

April 5, 2023

TITLE 38 ADDENDUM NO. 1

PROPOSAL FOR FURNISHING ALL LABOR, MATERIALS, EQUIPMENT, TRANSPORTATION, SUPERVISION, PERMITS, ETC. NECESSARY FOR FLOORING – AGNES EDWARDS 3RD AND 4TH FLOORS, LOCATED ON THE UL LAFAYETTE CAMPUS, LAFAYETTE, LOUISIANA.

Due April 20, 2023 2:00 PM Solicitation No. 23235

The following is to be made part of the original specifications as though issued at the same time and shall be incorporated integrally therewith. This addendum shall be acknowledged on the BID FORM when submitted to the Purchasing Department prior to the bid due date/time.

Item No. 1 - Change to the plans:

- a. Note #2 - Delete the words "TO DEMO EXISTING FLOORING, BASE, AND EXCESS GLUE IN AREAS NOTED BY "HATCH". CONTRACTOR SHALL SCRAPE, SAND, OR GRIND AS NEEDED TO REMOVE EXCESS GLUE FOR A SMOOTH SURFACE RECEIVING NEW FLOORING. CONTRACTOR SHALL REMOVE ALL BASE GLUE FROM WALLS TAKING CARE NOT TO DAMAGE EXISTING WALLS AND PAINT TO ALLOW NEW COVE BASE TO SIT FLAT ON WALLS."

All floors, base, and glue shall be removed by an abatement contractor prior to this contract.

Contractor shall be responsible for prepping the existing concrete floor according to the manufacturer's recommendations as well as installing floor patch as called for on the plans.

Item No. 2 - Change to the plans:

- a. Note #4 – Delete (4") and replace with 4-1/2". Cove base shall be 4-1/2".

Item No. 3 - Change to the specifications:

- a. Page 8 – under "New Flooring Installation" – Paragraph 5, change 4" to 4-1/2".

Item No. 4 – Clarification:

- a. There is NO subfloor under the existing flooring, just existing concrete slab.

Item No. 5 – Change to the plan and specification:

- a. Flooring tile size of 6" x 36" is acceptable in lieu of 6" x 48".

Item No. 6 – Clarification/Change to specification:

- a. Flooring tile wear layer shall be 30 mil in lieu of 8 mil.

Item No. 7 – Change to the plan and specification:

1. In "SCOPE OF WORK" in specification. Delete Note #1 – "Remove and reinstall existing furniture in each unit for flooring installation." All furniture shall be removed by the abatement contractor.
2. Plan Sheet A1 – Delete Note #1. FURNISH ALL LABOR TO REMOVE MOVABLE FURNITURE IN ALL ROOMS RECEIVING FLOORING (FURNITURE FURNISH ALL LABOR TO REMOVE MOVABLE FURNITURE IN ALL



Purchasing Office

P.O. Box 40197 • Lafayette, LA 70504-0197

Office: (337) 482-5396

Fax: (337) 482-5059

ROOMS RECEIVING FLOORING (FURNITURE MOVING CONSISTS OF 2 BEDS, 2 DESKS, AND 2 DRESSERS PER UNIT), INSTALL NEW FLOORING AND BASE AND REINSTALL FURNITURE IN ROOMS.

This is a public works bid. The addendum **MUST** be acknowledged with your bid on the BID FORM. For questions related to bidding these projects, please contact the UL Lafayette Purchasing Department at bids@louisiana.edu or 337.482.2955.

Marie C. Frank, MPA, CPPB
Assistant Vice President for Administration & Finance
University of Louisiana at Lafayette
Department of Purchasing